


Exova Warringtonfire  
Holmesfield Road  
Warrington  
WA1 2DS  
United Kingdom

T : +44 (0) 1925 655116  
F : +44 (0) 1925 655419  
E : warrington@exova.com  
W: www.exova.com



# Review of Fire Test Report



A Report To: Berica Cavi S.p.A.

Document Reference: 371404

**Date:** 4<sup>th</sup> October 2016

**Issue No.:** 1

Page 1

Testing  
Advising  
Assuring



## Executive Summary

**Objective** To review and extend the validity period of Exova Warringtonfire Test Report No: 177605 which details the fire performance of the following product when tested in accordance with BS EN 50200: 2006.


Generic Description	Product reference	Thickness c.s.a.	/	Weight per unit length
Cable	"Eurosafte FE 180"	9.3mm		128kg/km
<b>Individual components used to manufacture composite:</b>				
Conductors	"Solid Plain Annealed Copper Wire"	1.5mm <sup>2</sup>		13.52kg/km
Insulation	"Special Silicone Rubber"	0.8mm		22.6kg/km
Outer sheath	"Special Halogen Free LSZH"	1mm		37.6kg/km
<b>Please see page 4 of this test report for the full description of the product tested</b>				

**Test Sponsor** Berica Cavi S.p.A., Via della Meccanica, 2, 36040 Meledo di Sarego (VI), Italy.

**Conclusion** With respect to test report WF No. 177605, its contents shall remain valid until 4<sup>th</sup> November 2018.  
This review should be read in conjunction with test report WF No. 177605.


**Date of Test** 5<sup>th</sup> & 6<sup>th</sup> November 2008

## Signatories



---

Responsible Officer  
C. Meachin \*  
Technical Officer



---

Authorised  
S. Deeming \*  
Business Unit Head

\* For and on behalf of **Exova Warringtonfire**.

Report Issued: 4<sup>th</sup> October 2016

This version of the report has been produced from a .pdf format electronic file that has been provided by **Exova Warringtonfire** to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **Exova Warringtonfire**.

CONTENTS	PAGE NO.
EXECUTIVE SUMMARY .....	2
SIGNATORIES.....	2
TEST DETAILS.....	4
REVISION HISTORY .....	6



## Test Details

### Introduction

Test report WF No. 177605 relates to a test performed in accordance with the procedures defined in BS EN 50200: 2006, "Method of test for determining the resistance to fire of unprotected small cables for use in emergency circuits".

Product reference		"Eurosafte FE 180"
Cable marking		"EUROSAFE FE 180 4G1.5 UNSCR. FIRE RESISTANT BS6387 CWZ, EN 50200 PH 120, EN 60332-1-2, EN 61034-2, FIPEC(EN)50339-2-1 CE 09/08"
Cable function		Fire system connections
Number of cores x core size		4 x 1.5mm <sup>2</sup>
Voltage rating		300/500V
Overall diameter		9.3mm (stated by sponsor) 9.6mm (determined by <b>Exova Warringtonfire</b> )
Overall weight per unit length		128kg/km (stated by sponsor)
Conductors	Product reference	"Solid Plain Annealed Copper Wire"
	Generic type	Solid copper wire
	Name of manufacturer	<b>See Note 1 below</b>
	Cross sectional area	1.5mm <sup>2</sup>
	Weight per unit length	13.52kg/km
Insulation	Product reference	"Special Silicone Rubber"
	Generic type	Silicone rubber
	Name of manufacturer	FTC – Fabbrica Trentina Conduttori Srl
	Colour	"Black", "Blue", "Grey" and "Brown"
	Thickness	0.8mm
	Weight per unit length	22.6kg/km
Flame retardant details		<b>See Note 1 below</b>
Outer sheath	Product reference	"Special Halogen Free LSZH"
	Generic type	Low smoke zero halogen <b>See Note 1 below</b>
	Name of manufacturer	FTC – Fabbrica Trentina Conduttori Srl
	Colour	"Red"
	Thickness	1mm
	Weight per unit length	37.6kg/km
Flame retardant details		<b>See Note 1 below</b>
Brief description of manufacturing process		The conductor wires are insulated by extrusion of a continuous silicone rubber layer, which has been high temperature cross-linked. The cores are then twisted together. Finally, the sheathing is applied by a semi-compression extrusion process.

**Note 1: The sponsor of the test was unwilling to provide this or further information.**

**Test Results**

Test report WF No. 177605 contains the following results:

**When tested in accordance with BS EN 50200: 2006 in relation to the requirements for PH120 classification, the cable meets the criteria for resistance to fire with mechanical shock.**

**Confirmation  
Specification**

of Subsequent to the issue of the original test report, a representative of the sponsor of the test has stated that the sponsor has changed the name of the company. The correct name of the company is now Berica Cavi S.p.A. The new company name is referred to in this review report.

It has been confirmed in writing by Berica Cavi S.p.A. that there have been no changes to the product description contained within test report WF No. 177605 and that the product which is currently being manufactured is identical in every respect to the specimens which were tested.

It has also been confirmed in writing that no further fire testing of the previously fire tested specification has been performed since the issue of the test report, and no other individual or organisation has been asked to provide a technical review of the reports.

**Conclusions**

The procedures adopted for the original test (BS EN 50200: 2006) have been re-examined and are identical in all respects to those currently in use (BS EN 50200: 2015), therefore, with respect to test report WF No. 177605, its contents shall remain valid until 4<sup>th</sup> November 2018.

This review should be read in conjunction with test report WF No. 177605.

**Validity**

This review is based on information used in the original test report. No other information or data has been submitted by Berica Cavi S.p.A., which could affect this review.

## Revision History

Issue No :	Issue Date:
Revised By:	Approved By:
Reason for Revision:	

Issue No :	Issue Date:
Revised By:	Approved By:
Reason for Revision:	